

### Schedule of works

#### Upon arrival

Check for fault conditions on control panel

#### Control panel

Check internal control components

Check lamps

Check sounder

Check stepping relay (if applicable)

Check battery condition (if applicable)

#### Pump tank

Check pump tank

Wash down tank walls (where possible)

Check bleed port

#### Level controls

Check level controls

Check level controls sequence

#### Pump/s

Check for blockages

Check impellor rotation (only three phase)

Check fluids (oil, coolant)

Check moving parts (rotor, bearings)

Check resistance with electrical meter

Check amp draw with electrical meter

Wash down pump/s

### Schedule of works

#### Pipework and valves

Check internal pipework/fittings

Check valves (non-return and gate valves)

Check valves are clear of debris

Wash down internal pipework

Wash down valves

#### Final

Wet test system.

Check pump/s and level controls are in place and secure

Check pump/s running in Auto mode

Check pump/s impellor rotation correct (only three phase)

Check control panel closed and switched On

### Excluded

All connecting pipework/fittings to and from the tank

Incoming power supply

*Edincare may be unable to inspect all aspects of the equipment due to, for example, inaccessibility of equipment, adverse weather conditions, or where the customer has not followed the installation guidelines. Edincare Terms and Conditions apply.*

### NOTES